



EUC\MGB\MGB_EN_IP_R_127866.ema
Variant A
Multi-line
V1.0
==Safety=Safety_systems++MGB_EN_IP-127866/126635.a



EUC\MGB\MGB_EN_IP_R_127866.ema
Variant B
Multi-line
V1.0
==Safety=Safety_systems++MGB_EN_IP-127866/126635.a



-A19
/126635.a.1
/126635.a.1

Eingänge

Connection Header	Byte 0		Not-Halt-Schaltung	Byte 4		MGB-L	Byte 8	
	E2141.0	<input type="checkbox"/> RunMode		E2145.0	<input type="checkbox"/> F.I.E.S (Not-Halt)		E2149.0	<input type="checkbox"/> n.c.
	E2141.1	<input type="checkbox"/> ConnectionFaulted		E2145.1	<input type="checkbox"/> n.c.		E2149.1	<input type="checkbox"/> n.c.
	E2141.2	<input type="checkbox"/> DiagnosticActive		E2145.2	<input type="checkbox"/> n.c.		E2149.2	<input type="checkbox"/> S2 Taster
	E2141.3	<input type="checkbox"/> n.c.		E2145.3	<input type="checkbox"/> n.c.		E2149.3	<input type="checkbox"/> n.c.
	E2141.4	<input type="checkbox"/> n.c.		E2145.4	<input type="checkbox"/> n.c.		E2149.4	<input type="checkbox"/> S3 Taster
	E2141.5	<input type="checkbox"/> n.c.		E2145.5	<input type="checkbox"/> n.c.		E2149.5	<input type="checkbox"/> n.c.
	E2141.6	<input type="checkbox"/> n.c.		E2145.6	<input type="checkbox"/> n.c.		E2149.6	<input type="checkbox"/> n.c.
	E2141.7	<input type="checkbox"/> n.c.		E2145.7	<input type="checkbox"/> n.c.		E2149.7	<input type="checkbox"/> n.c.
	Byte 1			Byte 4			Byte 9	
	E2142.0	<input type="checkbox"/> DSC00		E2146.0	<input type="checkbox"/> F.I.D (Türstellung)		E2150.0	<input type="checkbox"/> n.c.
	E2142.1	<input type="checkbox"/> DSC01		E2146.1	<input type="checkbox"/> F.I.B (Riegelstellung)		E2150.1	<input type="checkbox"/> D.PF (Diagnostic Plausibilitätsfehler)
	E2142.2	<input type="checkbox"/> DSC02		E2146.2	<input type="checkbox"/> F.I.L (Zuhaltung)		E2150.2	<input type="checkbox"/> D.ES (Diagnostic Nothalt)
	E2142.3	<input type="checkbox"/> DSC03		E2146.3	<input type="checkbox"/> n.c.		E2150.3	<input type="checkbox"/> n.c.
	E2142.4	<input type="checkbox"/> DSC04		E2146.4	<input type="checkbox"/> n.c.		E2150.4	<input type="checkbox"/> n.c.
	E2142.5	<input type="checkbox"/> DSC05		E2146.5	<input type="checkbox"/> n.c.		E2150.5	<input type="checkbox"/> D.OL (Diagnostic Zuhaltern.)
	E2142.6	<input type="checkbox"/> DSC06		E2146.6	<input type="checkbox"/> F.I.SK (D und B)		E2150.6	<input type="checkbox"/> n.c.
	E2142.7	<input type="checkbox"/> DSC07		E2146.7	<input type="checkbox"/> F.I.UK (D und B und L)		E2150.7	<input type="checkbox"/> D.LT (Diagnostic Lebensdauer)
	Byte 2		Byte 6		Byte 10			
	E2143.0	<input type="checkbox"/> n.c.	E2147.0	<input type="checkbox"/> n.c.	E2151.0	<input type="checkbox"/> FC00		
	E2143.1	<input type="checkbox"/> n.c.	E2147.1	<input type="checkbox"/> n.c.	E2151.1	<input type="checkbox"/> FC01		
	E2143.2	<input type="checkbox"/> n.c.	E2147.2	<input type="checkbox"/> n.c.	E2151.2	<input type="checkbox"/> FC02		
	E2143.3	<input type="checkbox"/> n.c.	E2147.3	<input type="checkbox"/> n.c.	E2151.3	<input type="checkbox"/> FC03		
	E2143.4	<input type="checkbox"/> n.c.	E2147.4	<input type="checkbox"/> n.c.	E2151.4	<input type="checkbox"/> FC04		
	E2143.5	<input type="checkbox"/> n.c.	E2147.5	<input type="checkbox"/> n.c.	E2151.5	<input type="checkbox"/> FC05		
	E2143.6	<input type="checkbox"/> n.c.	E2147.6	<input type="checkbox"/> n.c.	E2151.6	<input type="checkbox"/> FC06		
	E2143.7	<input type="checkbox"/> n.c.	E2147.7	<input type="checkbox"/> n.c.	E2151.7	<input type="checkbox"/> FC07		
	Byte 3		Byte 7		Byte 11			
	E2144.0	<input type="checkbox"/> n.c.	E2148.0	<input type="checkbox"/> n.c.	E2152.0	<input type="checkbox"/> FC08		
	E2144.1	<input type="checkbox"/> n.c.	E2148.1	<input type="checkbox"/> n.c.	E2152.1	<input type="checkbox"/> FC09		
	E2144.2	<input type="checkbox"/> n.c.	E2148.2	<input type="checkbox"/> n.c.	E2152.2	<input type="checkbox"/> FC10		
	E2144.3	<input type="checkbox"/> n.c.	E2148.3	<input type="checkbox"/> n.c.	E2152.3	<input type="checkbox"/> FC11		
	E2144.4	<input type="checkbox"/> n.c.	E2148.4	<input type="checkbox"/> n.c.	E2152.4	<input type="checkbox"/> FC12		
	E2144.5	<input type="checkbox"/> n.c.	E2148.5	<input type="checkbox"/> n.c.	E2152.5	<input type="checkbox"/> FC13		
	E2144.6	<input type="checkbox"/> n.c.	E2148.6	<input type="checkbox"/> n.c.	E2152.6	<input type="checkbox"/> FC14		
	E2144.7	<input type="checkbox"/> n.c.	E2148.7	<input type="checkbox"/> n.c.	E2152.7	<input type="checkbox"/> FC15		
	Diagnostic Sequence Count (8 Bit Wert)		MGB-B		Diagnosemodul			
					Fault Code (16 Bit Wert)			





Diagnostic
Sequence
Count
(8 Bit Wert)

Fault
Code
(16 Bit Wert)

Ausgänge

Auswertemodul	Byte 0	Busmodul	Byte 1
	A1814.0 <input type="checkbox"/> FO.L (Zuhaltung)		A1815.0 <input type="checkbox"/> n.c.
	A1814.1 <input type="checkbox"/> n.c.		A1815.1 <input type="checkbox"/> n.c.
	A1814.2 <input type="checkbox"/> n.c.		A1815.2 <input type="checkbox"/> n.c.
	A1814.3 <input type="checkbox"/> n.c.		A1815.3 <input type="checkbox"/> n.c.
	A1814.4 <input type="checkbox"/> n.c.		A1815.4 <input type="checkbox"/> n.c.
	A1814.5 <input type="checkbox"/> n.c.		A1815.5 <input type="checkbox"/> n.c.
	A1814.6 <input type="checkbox"/> n.c.		A1815.6 <input type="checkbox"/> n.c.
	A1814.7 <input type="checkbox"/> n.c.		A1815.7 <input type="checkbox"/> n.c.
Auswertemodul	Byte 2	Diagnosemodul	Byte 3
	A1816.0 <input type="checkbox"/> LED; H1		A1817.0 <input type="checkbox"/> n.c.
	A1816.1 <input type="checkbox"/> LED; H2		A1817.1 <input type="checkbox"/> n.c.
	A1816.2 <input type="checkbox"/> LED; H3		A1817.2 <input type="checkbox"/> n.c.
	A1816.3 <input type="checkbox"/> n.c.		A1817.3 <input type="checkbox"/> n.c.
	A1816.4 <input type="checkbox"/> n.c.		A1817.4 <input type="checkbox"/> n.c.
	A1816.5 <input type="checkbox"/> n.c.		A1817.5 <input type="checkbox"/> n.c.
	A1816.6 <input type="checkbox"/> n.c.		A1817.6 <input type="checkbox"/> Q.G (Quittieren Busfehler)
	A1816.7 <input type="checkbox"/> n.c.		A1817.7 <input type="checkbox"/> Q.PF (Quittieren Plausibilitätsfehler)

EUCHNER | MGB
126635
MGB-L1B-EIA-R



EUC\MGB\MGB_EN_IP_R_127866.ema
Variant B
Overview
V1.0
==Safety==Safety_systems++MGB_EN_IP-127866/126635.c

