

| | | | | | | | | | | |
|----------|-------|------|--------|----------|---|---------------|--|------------------|------------------|--|
| | | | Datum | 13.04.16 | <div style="text-align: center; font-size: 2em; font-weight: bold; color: red;">EUCHNER</div> | | Artikelnummer: 115415.a | Typ: Eplan Makro | = Safety_systems | |
| | | | Bearb. | avara | | | | | ++ MGB_PN | |
| | | | Gepr | | | | | | | |
| Änderung | Datum | Name | Urspr | | Ersatz von | Ersetzt durch | | | | |

Eingänge




| | | | |
|-------------------|--|---------------|---|
| Busmodul | Slot 1 / Byte 0 | Diagnosemodul | Slot 4 / Byte 0 |
| | E1154.0 <input type="checkbox"/> S90 Taster E1154.1 <input type="checkbox"/> S91 Taster E1154.2 <input type="checkbox"/> n.c. E1154.3 <input type="checkbox"/> n.c. E1154.4 <input type="checkbox"/> n.c. E1154.5 <input type="checkbox"/> S95 Taster E1154.6 <input type="checkbox"/> n.c. E1154.7 <input type="checkbox"/> n.c. | | E1158.0 <input type="checkbox"/> Meldung liegt an. Profisafe E1158.1 <input type="checkbox"/> Meldung 274(4) E1158.2 <input type="checkbox"/> n.c. E1158.3 <input type="checkbox"/> Meldung 272(2) oder 273(2) E1158.4 <input type="checkbox"/> n.c. E1158.5 <input type="checkbox"/> n.c. E1158.6 <input type="checkbox"/> n.c. E1158.7 <input type="checkbox"/> Meldung 274(1) |
| Auswertemodul | Slot 1 / Byte 1 | PROFIsafe | Slot 5 / Byte 0 |
| | E1155.0 <input type="checkbox"/> n.c. E1155.1 <input type="checkbox"/> n.c. E1155.2 <input type="checkbox"/> n.c. E1155.3 <input type="checkbox"/> n.c. E1155.4 <input type="checkbox"/> n.c. E1155.5 <input type="checkbox"/> n.c. E1155.6 <input type="checkbox"/> n.c. E1155.7 <input type="checkbox"/> n.c. | | E1159.0 <input type="checkbox"/> n.c. E1159.1 <input type="checkbox"/> Zustimmtaster E1159.2 <input type="checkbox"/> T (Türstellung) E1159.3 <input type="checkbox"/> R (Riegelstellung) E1159.4 <input type="checkbox"/> Z (Zuhaltung) E1159.5 <input type="checkbox"/> n.c. E1159.6 <input type="checkbox"/> n.c. E1159.7 <input type="checkbox"/> n.c. |
| Zustimmtastermod. | Slot 2 / Byte 0 | | Slot 5 / Byte 1 |
| | E1156.0 <input type="checkbox"/> T (Türstellung) E1156.1 <input type="checkbox"/> R (Riegelstellung) E1156.2 <input type="checkbox"/> Z (Zuhaltung) E1156.3 <input type="checkbox"/> n.c. E1156.4 <input type="checkbox"/> n.c. E1156.5 <input type="checkbox"/> n.c. E1156.6 <input type="checkbox"/> SK (T UND R) E1156.7 <input type="checkbox"/> ÜK (T UND R UND Z) | | E1160.0 <input type="checkbox"/> SK (T UND R) E1160.1 <input type="checkbox"/> ÜK (T UND R UND Z) E1160.2 <input type="checkbox"/> n.c. E1160.3 <input type="checkbox"/> n.c. E1160.4 <input type="checkbox"/> n.c. E1160.5 <input type="checkbox"/> n.c. E1160.6 <input type="checkbox"/> n.c. E1160.7 <input type="checkbox"/> n.c. |
| | Slot 3 / Byte 0 | | |
| | E1157.0 <input type="checkbox"/> Zustimmtaster in Stellung "Zustimmung" E1157.1 <input type="checkbox"/> n.c. E1157.2 <input type="checkbox"/> n.c. E1157.3 <input type="checkbox"/> n.c. E1157.4 <input type="checkbox"/> n.c. E1157.5 <input type="checkbox"/> Zummistaster Taste + E1157.6 <input type="checkbox"/> Zummistaster Taste - E1157.7 <input type="checkbox"/> Zummistaster Haltererkennung | | |

EUCHNERMGB

115415
MGB-L2B-PNC-R

Ausgänge

| | | | |
|-------------------|--|---------------|---|
| Busmodul | Slot 1 / Byte 0 | Diagnosemodul | Slot 4 / Byte 0 |
| | A1021.0 <input type="checkbox"/> LED; H90 A1021.1 <input type="checkbox"/> LED; H91 A1021.2 <input type="checkbox"/> n.c. A1021.3 <input type="checkbox"/> n.c. A1021.4 <input type="checkbox"/> n.c. A1021.5 <input type="checkbox"/> LED; H95 A1021.6 <input type="checkbox"/> n.c. A1021.7 <input type="checkbox"/> n.c. | | A1024.0 <input type="checkbox"/> Gerätediagnose: Meldung quittieren A1024.1 <input type="checkbox"/> Reset MGB Zuhaltmodul: Meldung quittieren A1024.2 <input type="checkbox"/> n.c. A1024.3 <input type="checkbox"/> n.c. A1024.4 <input type="checkbox"/> n.c. A1024.5 <input type="checkbox"/> n.c. A1024.6 <input type="checkbox"/> n.c. A1024.7 <input type="checkbox"/> n.c. |
| Auswertemodul | Slot 2 / Byte 0 | PROFIsafe | Slot 5 / Byte 0 |
| | A1022.0 <input type="checkbox"/> Zuhaltmagnet - Steuerspannung ein A1022.1 <input type="checkbox"/> n.c. A1022.2 <input type="checkbox"/> n.c. A1022.3 <input type="checkbox"/> n.c. A1022.4 <input type="checkbox"/> n.c. A1022.5 <input type="checkbox"/> n.c. A1022.6 <input type="checkbox"/> n.c. A1022.7 <input type="checkbox"/> n.c. | | A1025.0 <input type="checkbox"/> Zuhaltmagnet - Steuerspannung ein A1025.1 <input type="checkbox"/> n.c. A1025.2 <input type="checkbox"/> n.c. A1025.3 <input type="checkbox"/> n.c. A1025.4 <input type="checkbox"/> n.c. A1025.5 <input type="checkbox"/> n.c. A1025.6 <input type="checkbox"/> n.c. A1025.7 <input type="checkbox"/> n.c. |
| Zustimmtastermod. | Slot 3 / Byte 0 | | Slot 5 / Byte 1 |
| | A1023.0 <input type="checkbox"/> Zustimmtaster Beleuchtung für Taste + A1023.1 <input type="checkbox"/> Zustimmtaster Beleuchtung für Taste - A1023.2 <input type="checkbox"/> n.c. A1023.3 <input type="checkbox"/> n.c. A1023.4 <input type="checkbox"/> n.c. A1023.5 <input type="checkbox"/> n.c. A1023.6 <input type="checkbox"/> n.c. A1023.7 <input type="checkbox"/> n.c. | | A1026.0 <input type="checkbox"/> n.c. A1026.1 <input type="checkbox"/> n.c. A1026.2 <input type="checkbox"/> n.c. A1026.3 <input type="checkbox"/> n.c. A1026.4 <input type="checkbox"/> n.c. A1026.5 <input type="checkbox"/> n.c. A1026.6 <input type="checkbox"/> n.c. A1026.7 <input type="checkbox"/> n.c. |



EUC\MGB\MGB_PNC_R_114412.ema
Variant B
Overview
V2.0
==Safety==Safety_systems++MGB_PN+PNC-114412/115415.c

